

CLIENT INFORMATION

Name:	New Lebanon Central School District
Address:	14665 NY 22 New Lebanon, NY 12125
Client Rep:	

Date of Sampling:
Samples Taken By:
Samples Taken By:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Walter B Howard Elementary
BLDG ADDRESS:	1478 Rt 20 New Lebanon, NY 12125
CONTACT NAME & NUMBERS:	

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead	Copper	Remediation
1	WBH-01-DW-P-01	Fountain	Café North Wall							OFF-Covid
2	WBH-01-BF-P-02	Bathroom Faucet	Woman's Bathroom by Cafe Right			X		1.3		
3	WBH-01-BF-P-03	Bathroom Faucet	Women's Bathroom by Cafe Center			X		1.5		
4	WBH-01-BF-P-04	Bathroom Faucet	Women's Bathroom by Cafe Left			X		1.2		
5	WBH-01-BFP-04	Bathroom Faucet	Men's Room Main Lobby			X		4.7		
6	WBH-01-DW-P-06	Fountain	Main Lobby Area			X		X		
7	WBH-01-BF-P-07	Bathroom Faucet	Main Office Bathroom			X		28.1		
8	WBH-01-IM-P-08	Ice Machine	Nurses Office Ice Machine			X		15.2		
9	WBH-01-NS-P-09	Sink Faucet	Nurses Office			X		10.8		
10	WBH-01-BF-P-10	Bathroom Faucet	Nurse's Office Bathroom			X		1.3		
11	WBH-01-DW-P-11	Fountain	Classroom #2							OFF-Covid
12	WBH-01-SF-P-12	Sink Faucet	Classroom #2			X		4.2		
13	WBH-01-BF-P-13	Bathroom Faucet	Classroom 2 Bathroom			X		4.4		
14	WBH-01-SF-P-14	Sink Faucet	Classroom #3			X		12.3		
15	WBH-01-DW-P-15	Bubbler	Classroom #3							OFF-Covid
16	WBH-01-BF-P-16	Bathroom Faucet	Classroom 3 Bathroom North			X		1030		
17	WBH-01-BF-P-17	Bathroom Faucet	Classroom 3 Bathroom South			X		X		OFF
18	WBH-01-SF-P-18	Sink Faucet	Classroom #4 OT/PT			X		16.2		
19	WBH-01-DW-P-19	Bubbler	Classroom #4 OT/PT							OFF-Covid

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name:	New Lebanon Central School District
Address:	14665 NY 22 New Lebanon, NY 12125
Client Rep:	

Date of Sampling:
Samples Taken By:
Samples Taken By:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Walter B Howard Elementary
BLDG ADDRESS:	1478 Rt 20 New Lebanon, NY 12125
CONTACT NAME & NUMBERS:	

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead	Copper	Remediation
20	WBH-01-BF-P-20	Sink Faucet	Bathroom Near Rm 5 west			X		2.9		
21	WBH-01-BF-P-21	Sink Faucet	Bathroom Near Rm 5 east			X		X		OFF
22	WBH-01-SF-P-22	Sink Faucet	Classroom #5			X		12.1		
23	WBH-01-DW-P-23	Bubbler	Classroom #5							OFF-Covid
24	WBH-01-BF-P-24	Bathroom Faucet	Classroom 5 Bathroom			X		X		OFF
25	WBH-01-SF-P-25	Sink Faucet	Classroom #6			X		6.8		
26	WBH-01-DW-P-26	Bubbler	Classroom #6							OFF-Covid
27	WBH-01-BF-P-27	Bathroom Faucet	Classroom 6/7 Bathroom			X		<1		
28	WBH-01-SF-P-28	Sink Faucet	Classroom #7			X		3.9		
29	WBH-01-DW-P-29	Bubbler	Classroom #7							OFF-Covid
30	WBH-01-SF-P-30	Sink Faucet	Classroom #8			X		17.9		
31	WBH-01-DW-P-31	Bubbler	Classroom #8			X		30.4		
32	WBH-01-BF-P-32	Bathroom Faucet	Classroom 8 Bathroom							OFF-Covid
33	WBH-01-SF-P-33	Sink Faucet	Classroom #9			X		<1		
34	WBH-01-DW-P-34	Bubbler	Classroom#9							OFF-Covid
35	WBH-01-BF-P-35	Bathroom Faucet	Classroom 9 Bathroom			X		8.5		
36	WBH-01-SF-P-36	Sink Faucet	Classroom #10			X		4.8		
37	WBH-01-DW-P-37	Bubbler	Classroom #10							OFF-Covid
38	WBH-01-BF-P-38	Bathroom Faucet	Classroom 10 Bathroom			X		17.3		
39	WBH-01-SF-P-39	Sink Faucet	Classroom #11			X		<1		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	PACE
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name:	New Lebanon Central School District
Address:	14665 NY 22 New Lebanon, NY 12125
Client Rep:	

Date of Sampling:
Samples Taken By:
Samples Taken By:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Walter B Howard Elementary
BLDG ADDRESS:	1478 Rt 20 New Lebanon, NY 12125
CONTACT NAME & NUMBERS:	

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead	Copper	Remediation
40	WBH-01-DW-P-40	Bubbler	Classroom #11							OFF-Covid
41	WBH-01-BF-P-41	Bathroom Faucet	Classroom 11 Bathroom			X		16.8		
42	WBH-01-SF-P-42	Sink Faucet	Classroom #12			X		4.8		
43	WBH-01-DW-P-43	Bubbler	Classroom #12							OFF-Covid
44	WBH-01-BF-P-44	Bathroom Faucet	Classroom 12 Bathroom			X		1.2		
45	WBH-01-SF-P-45	Sink Faucet	Classroom #13			X		1.9		
46	WBH-01-DW-P-46	Bubbler	Classroom #13							OFF-Covid
47	WBH-01-BF-P-47	Bathroom Faucet	Classroom 13/15 Bathroom			X		1.7		
48	WBH-01-SF-P-48	Sink Faucet	Classroom #14 Bathroom			X		34.9		
49	WBH-01-DW-P-49	Bubbler	Classroom #14							OFF-Covid
50	WBH-01-SF-P-50	Sink Faucet	Classroom #15			X		1.8		
51	WBH-01-DW-P-51	Bubbler	Classroom #15							OFF-Covid
52	WBH-01-SF-P-52	Sink Faucet	Classroom #16			X		2.6		
53	WBH-01-DW-P-53	Bubbler	Classroom #16							OFF-Covid
54	WBH-01-BF-P-54	Bathroom Faucet	Classroom 16 Bathroom			X		<1		
55	WBH-01-SF-P-55	Faucet	Classroom #74			X		27.7		
56	WBH-01-SF-P-56	Faucet	Classroom #73			X		1.9		
57	WBH-01-DW-P-57	Fountain	Corr by Rm 75							OFF-Covid
58	WBH-01-BF-P-58	Sink Faucet	Bathroom Near Rm 73			X		3.8		
59	WBH-01-SF-P-59	Sink Faucet	Classroom #17			X		15.9		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	PACE
Contact:	
Comments:	Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

Name:	New Lebanon Central School District
Address:	14665 NY 22 New Lebanon, NY 12125
Client Rep:	

Date of Sampling:

Samples Taken By:

Samples Taken By:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME:	Walter B Howard Elementary
BLDG ADDRESS:	1478 Rt 20 New Lebanon, NY 12125
CONTACT NAME & NUMBERS:	

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead	Copper	Remediation
60	WBH-01-DW-P-60	Bubbler	Classroom #17							OFF-Covid
61	WBH-01-BF-P-61	Bathroom Faucet	Classroom 17 Bathroom			X		36.6		
62	WBH-01-SF-P-62	Sink Faucet	Classroom 18 North			X		2.8		
63	WBH-01-SF-P-63	Sink Faucet	Classroom 18 South			X		8.3		
64	WBH-01-BF-P-64	Bathroom Faucet	Classroom 18/19 Bathroom			X		2.1		
65	WBH-01-SF-P-65	Sink Faucet	Classroom #19			X		4.2		
66	WBH-01-DW-P-66	Bubbler	Classroom#19							OFF-Covid
67	WBH-01-SF-P-67	Sink Faucet	Classroom #20			X		3		
68	WBH-01-DW-P-68	Bubbler	Classroom #20							OFF-Covid
69	WBH-01-BF-P-69	Bathroom Faucet	Classroom 20/21 Bathroom North			X		39.2		
70	WBH-01-BF-P-70	Bathroom Faucet	Classroom 20/21 Bathroom South			X		8.8		
71	WBH-01-SF-P-71	Sink Faucet	Classroom #21			X		4.2		
72	WBH-01-DW-P-72	Bubbler	Classroom #21							OFF-Covid
73	WBH-01-SF-P-73	Sink Faucet	Classroom #22			X		3.1		
74	WBH-01-DW-P-74	Bubbler	Classroom #22							OFF-Covid
75	WBH-01-BF-P-75	Bathroom Faucet	Classroom 22 Bathroom			X		22.9		
76	WBH-01-SF-P-76	Sink Faucet	Faculty Room			X		2.8		
77	WBH-01-BF-P-77	Bathroom Faucet	Faculty Bathroom North			X		4.7		
78	WBH-01-BF-P-78	Bathroom Faucet	Faculty Bathroom South			X		<1		

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab:	PACE
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMANTION

Name:	New Lebanon Central School District
Address:	14665 NY 22 New Lebanon, NY 12125
Client Rep:	

Date of Sampling:
Samples Taken By:
Samples Taken By:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Walter B Howard Elementary
BLDG ADDRESS: 1478 Rt 20 New Lebanon, NY 12125
CONTACT NAME & NUMBERS:

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead	Copper	Remediation
79	WBH-01-KS-P-79	Faucet	Kitchen Center Wall West			X		1.2		
80	WBH-01-KS-P-80	Faucet	Kitchen Center Wall East			X		<1		
81	WBH-01-BF-P-81	Faucet	Kitchen			X		<1		
82	WBH-01-KS-P-82	Faucet	Kitchen West Near Bathroom			X		X		OFF
83	WBH-01-KS-P-83	Faucet	Kitchen East Near Bathroom			X		X		OFF
84	WBH-01-KS-P-84	Faucet	Kitchen Serving Area			X		1.3		
85	WBH-01-KS-P-85	Wall Faucet	Kitchen Near Dishwasher			X		X		OFF
86	WBH-01-BF-P-86	Bathroom Faucet	Boys Library			X		7		
87	WBH-01-BF-P-87	Bathroom Faucet	Girls Library			X		10.3		

All containers are cleaned/are certified 250-ml bottles with 100% deionized water.

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO₃@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for lead (Pb)

Lab: PACE	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	